



MR. SREENIVASA RAO
SIGMA CORP
700 GOLDMAN DR
CREAMRIDGE NJ 08514

Date: 2013/09/18
Subscriber: 544167001
PartySite: 107767
File No: EX26385
Project No: 13NB03193
PD No: 13M39582
Type: R
PO Number:

Subject: **Procedure And/Or Report Material**

The following material resulting from the investigation under the above numbers is enclosed.

Issue

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
	1		Revised Authorization Page(s)	2013/09/17
	1		Marking Data Page(s)	
2013/08/21	1	1	Cert of Compliance	
2013/08/21	1		Cover Page(s)	
2013/08/21	1		Revised Description Page(s) 1	2013/09/17
2013/08/21	1		New Test Record 2	2013/09/17
2013/08/21	1		Revised Test Record i, 1-2	2013/09/17

SR# 11228.

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://www.ul.com/global/eng/pages/corporate/contactus>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above.

This material is provided on behalf of UL LLC(UL) or any authorized licensee of UL.

NBK File



File EX26385

Vol 1

Auth. Page 1

Issued: 2013-08-21

Revised: 2013-09-17

FOLLOW-UP SERVICE PROCEDURE
(TYPE R)

INDICATOR POSTS, GATE VALVE
(HCBZ,HCBZ7)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: 559880 (Party Site)
SIGMA CORP
(544167-001) 700 GOLDMAN DR
CREAM RIDGE NJ 08514-2528

Listee/Classified Co.: 559880 (Party Site)
SAME AS APPLICANT
(544167-001)

This Follow-Up Service Procedure authorizes the above Manufacturer(s) to use the marking specified by UL LLC, or any authorized licensee of UL LLC, including the UL Contracting Party, only on products when constructed, tested and found to be in compliance with the requirements of this Follow-Up Service Procedure and in accordance with the terms of the applicable service agreement with UL Contracting Party and any applicable Service Terms. The UL Contracting Party for Follow-Up Services is listed on addendum to this Follow-Up Service Procedure ("UL Contracting Party"). UL Contracting Party and UL LLC are referred to jointly herein as "UL."

UL further defines responsibilities, duties and requirements for both Manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in the document titled "UL and Subscriber Responsibilities" that can be located at the following website: <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of these documents from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of these documents or the applicable Service Terms, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified Manufacturer(s) and any Listee/Classified Co. in this Follow-Up Service Procedure must agree to receive Follow-Up Services from UL Contracting Party. If your applicable agreement is a Global Services Agreement ("GSA") with an effective date of January 1, 2012 or later and this Follow-Up Service Procedure is issued on or after that effective date, the Applicant, the specified Manufacturer(s) and any Listee/Classified Co. will be bound to a Service Agreement for Follow-Up Services upon the earliest by any Subscriber of use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees which will incorporate such GSA, this Follow-Up Service Procedure and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/Terms-After-12-31-2011>. In all other events, Follow-Up Services will be governed by and incorporate the terms of your applicable service agreement and this Follow-Up Service Procedure.

It is the responsibility of the Listee/Classified Co. to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL LLC, or any authorized licensee of UL LLC.

This Follow-Up Service Procedure contains information for the use of the above Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is provided to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Follow-Up Service Procedure, and any subsequent revisions, is the property of UL and is not transferable. This Follow-Up Service Procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is provided to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

Capitalized terms used but not defined herein have the meanings set forth in the GSA and the applicable Service Terms or any other applicable UL service agreement.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Follow-Up Service Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL LLC or an authorized licensee of UL LLC, including UL Contracting Party, and the Manufacturer(s).

UL LLC has signed below solely in its capacity as the accredited entity to indicate that this Follow-Up Service Procedure is in compliance with the accreditation requirements.

William R. Carney
Director
North American Certification Program

LOCATION

(100607--170) 592228 (Party Site)
ANHUI WOR-BIZ TRADING CO LTD
18/FL CHANGHE MANSION, NO. 677
WEST CHANGJIANG ROAD
HEFEI
ANHUI 230088 CHINA
Factory ID: None
UL Contracting Party for above site is: UL AG

(FILE IMMEDIATELY AFTER AUTHORIZATION PAGE)

LISTING MARK

The Listing Mark consists of four elements placed in close proximity and shall appear on Listed products only. Minimum size is not specified, as long as the Listing Mark is legible. The following is suggested.



XXXX = The control number assigned by UL, EX26385.

The minimum height of the registered trademark symbol ® shall be 3/64 of an inch. When the overall diameter of the UL Mark is less than 3/8 of an inch, the trademark symbol may be omitted if it is not legible to the naked eye.

The product identity is: "FIRE MAIN INDICATOR POST".

The product identity may be omitted if the Mark is directly and permanently applied to the product by stamping, molding, ink-stamping, silk screening or similar process. The product identity may appear elsewhere on the product if the other three elements are part of the nameplate which includes the rating or the catalog or model designation.

Separable Listing Mark (not part of a nameplate and in the form of decals, stickers or labels) will always include the four elements.

The manufacturer may reproduce the Mark or obtain it from a UL authorized supplier.

THIS PAGE IS TO BE REVISED BY FUS DEPARTMENT ONLY

Canadian Listing Mark Data Page

(FILE IMMEDIATELY AFTER AUTHORIZATION PAGE)

LISTING MARK

The Listing Mark consists of four elements placed in close proximity and shall appear on Listed products only. Minimum size is not specified, as long as the Listing Mark is legible. The following is suggested. (If only Canadian coverage is authorized, use only the C-UL Symbol).

UL Symbol to the left and the C-UL Symbol to the right.



Alternatively, the Canadian/US Mark may be used. The UL Symbol with "C" to the left and "US" to the right.



XXXX = The control number assigned by UL, EX26385.

The minimum height of the registered trademark symbol ® shall be 3/64 of an inch. When the overall diameter of the UL Mark is less than 3/8 of an inch, the trademark symbol may be omitted if it is not legible to the naked eye.

The product identity is: "FIRE MAIN INDICATOR POST"

The product identity may appear elsewhere on the product when the other three elements are directly and permanently applied to the product by stamping, molding, ink-stamping, silk screening or similar process or part of the nameplate which includes the rating or the catalog or model designation.

Separable Listing Mark (not part of a nameplate and in the form of decals, stickers or labels) will always include the four elements.

The manufacturer may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized label suppliers can be found on UL's online directory at www.ul.com.

CERTIFICATE OF COMPLIANCE

Certificate Number 20130918-EX26385
Report Reference EX26385-20130821
Issue Date 2013-SEPTEMBER-18

Issued to: SIGMA CORP
700 GOLDMAN DR
CREAMRIDGE NJ 08514

**This is to certify that
representative samples of**

INDICATOR POSTS, GATE VALVE

Intended for use with valves controlling water supplies to
sprinkler, deluge, water spray, foam and standpipe systems
used in private service where connections enter the building
in the following Models, types and sizes:

Model D-UFP011;

Type: Underground – Adjustable;

Intended for Valve Size, NPS: 3-14

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 789, Indicator Posts for Fire-Protection Service;
ULC/ORD-C789, Guide for the Investigation of Indicator
Posts for Fire-Protection Service

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US
and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL;
and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus





File EX26385
Project 4786037359
SR 11228

Issued: August 21, 2013
Revised: September 17, 2013

REPORT

On

INDICATOR POSTS, GATE VALVE

Sigma Corporation
Cream Ridge, NJ

Copyright © 2013 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

USL, CNL - Model D-UFP011 - Underground type, vertical, adjustable length.

INTRODUCTION:

This report covers the investigation of indicator post for gate valves intended to be installed in accordance with the manufacturer's installation instructions and the National Fire Protection Association Standards, NFPA 11, NFPA 13, NFPA 14 and NFPA 24.

OBJECT:

The object of this investigation was to determine compliance of the Indicator Posts for Gate Valves with the requirements of the Standard for Indicator Posts for Fire Protection Service, UL 789 and the Guide for the Investigation of Indicator Posts for Fire Protection Service, ULC/ORD-C789-1975.

PLAN:

The investigation of the indicator posts consisted of conducting a product evaluation and performance testing as described in UL789, 10th Edition and ULC/ORD-C789-1975, 1st Edition.

TEST RECORD INDEX

DESCRIPTION	TEST RECORD NO.
Model D-UFP011 adjustable indicator posts for gate valves.	1
CUL Listing for Model D-UFP011 adjustable indicator posts for gate valves.	2

Test results relate only to the items tested.

The following tests were waived:

Test	Rationale for Waived Test ⁺	File Reference	Report Date	Test Record No.
Elastomeric Parts Test	1	-	-	-

1. Elastomeric parts testing was considered not necessary since the only elastomeric material utilized is the gasket on the glass cover.

Standard	Title	Edition or Publication Date	Latest Revision Date
UL789	Standard for Indicator Posts for Fire-Protection Service	10 th	2012-11-09
*			

TEST RECORD NO. 2


SAMPLES:

Model	Type	Intended for Valve Size, mm
CNL - D-UFP011	Underground - Adjustable	76.2-355.6


No testing was required. The product was tested with complying results in accordance with UL789 - Standard for Indicator Posts for Fire-Protection Service. No requirements needed to attain CUL Listing.

Standard	Title	Edition or Publication Date	Latest Revision Date
CUL/ORD-C789	Guide for the Investigation of Indicator Posts for Fire-Protection Service	1 st	Jan. 1975

Very truly yours,
Reviewed by:



John R. Serpe
Senior Engineering Associate



Michael G. McCormick
Staff Engineering Associate

Any information and documentation provided to you involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.